



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



July 10, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mark Anthony
15111 SR 664 South
Logan, OH 43138

Hocking County
Valleyview Estates MHP PWS
Community PWS
PWS ID: OH3700312

Dear Mr. Anthony:

The Public Water System (PWS) serving Valleyview Estates MHP is in violation of the Ohio Administrative Code (OAC) for:

Failure to Notify OEPA of major emergencies:


This letter serves as a notice of violation for failure to notify the Southeast District Office (SEDO) of the loss of electricity to the PWS treatment plant on July 2, 2012, at 8:30 pm. The Operator of Record, Jim Bennett WS3-1013834-01, notified SEDO via phone at 9:42 pm on July 3, 2012. The system had depressurized and was without means to re-energize the treatment plant for the entire outage that lasted until July 7, 2012, at 1:30 pm.

OAC 3745-83-01(H)(4) requires the discovery of any serious plant breakdown or condition causing or likely to cause any of the following items be reported to the district office as soon as possible, but within twenty-four hours:

- (a) Any discharge of water not in accordance with section 6109. of the Revised Code or the rules adopted thereunder;
- (b) Any major interruption in service or disinfection; or
- (c) Any hazard for employees, consumers, the public, or the environment.

If you have any questions please call me at 740-380-5229.

Sincerely,


Russell Flagg

RF/cb

cc: C.O. - DDAGW / OFAS / Dave Riley
cc: Hocking County Health Dept.
cc: Jim Bennett, Operator
20355 Carroll Rd
Rockbridge, OH 43149

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov