



State of Ohio Environmental Protection Agency

**Southwest District Office**

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 27, 2010

Re: **North Hampton**  
Clark County  
Community Water System  
PWS ID: 1203412

North Hampton Village  
Attn: Troy Wildman  
P.O. Box 307  
North Hampton, OH 45349

**Subject: Monthly Operating Report, Failure to Submit**

Dear Mr. Wildman:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **December 2009**, the Village of North Hampton public water system did send the monthly report to this office. However, there were at least thirteen days of missing data for the free and total chlorine residuals in the distribution and at the plant tap. This is a violation of the rule. The Village of North Hampton public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

**Tya Darden**

Division of Drinking and Groundwaters  
Public Drinking Water Unit

cc: Dave Bornino, Ohio EPA, DDAGW, CO  
Board of Directors

ec: Clark County Health Department  
TD\bp