



State of Ohio Environmental Protection Agency

**Southwest District Office**

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 27, 2010

Re: **Brookside Village MHP**  
Clark County  
Community Water System  
PWS ID: 1200112

Brookside Village MHP  
Peter Stojich  
6104 Whiting  
McHenry, IL 60050

**Subject: Monthly Operating Report, Failure to Submit**

Dear Mr. Stojich:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **December 2009**, Brookside Village MHP public water system failed to monitor for the free and total chlorine residuals daily at the plant tap and in the distribution. The report contains at least six days of missing chlorine residuals in the distribution and at the plant tap. This is a violation of the rule. Brookside Village MHP public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that the free and total chlorine residuals are taken in the distribution system and at the plant tap.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

**Tya Darden**

Division of Drinking and Groundwaters  
Public Drinking Water Unit

CC: Dave Evans, Ohio EPA, DDAGW, CO  
Charles Crosbie

TD\bp