



State of Ohio Environmental Protection Agency

Southwest District

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937)285-6357 FAX: (937)285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korieski, Director

March 3, 2009

Re: North Hampton Village  
Clark County  
Community Water System  
PWS ID: 1203412

North Hampton Village  
Attn: Troy Wildman  
P.O. Box 307  
North Hampton, OH 45349

**Subject: Monthly Operating Report, Failure to Submit**

Dear Mr. Wildman:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of January 2009, the Village of North Hampton public water system failed to send the monthly report to this office. This is a violation of the rule. The Village of North Hampton public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

Tya Darden

Division of Drinking and Groundwaters  
Public Drinking Water Unit

cc: Dave Evans, Ohio EPA, DDAGW, CO  
File

TD/mab