



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Notice of Violation  
Auglaize County  
~~Beverly Hills Subdivision~~  
K/Z Sewer District  
Pleasantview Estates Subdivision  
Uniopolis WWTP  
NPDES Permits

October 5, 2010

Mr. Douglas P. Reinhart  
Auglaize County Engineer  
P. O. Box 59  
Wapakoneta, Ohio 45895

Dear Mr. Reinhart:

We are in receipt of your self-monitoring reports covering the months of April through June 2010 for the above referenced facilities. Our review indicates violations of the conditions of those NPDES permits. The specific instances of noncompliance are attached on separate sheets. Further review of your self-monitoring reports for the previous six months, ending in June 2010 for Beverly Hills Subdivision and K/Z Sewer District, indicates that you are in significant non-compliance (SNC) with two effluent limitations contained in your NPDES permits. The specific instances of SNC are attached on separate sheets.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Mr. Douglas P. Reinhart  
October 5, 2010  
Page Two

If there are any questions, please contact me at (419) 373-3022.

Sincerely,

A handwritten signature in cursive script that reads "Justin A. Williams".

Justin A. Williams  
Division of Surface Water

/cs

Enclosures

pc:w/Enclosures-NWDO-DSW-File(4)

Get New Data

Violations for Beverly Hills Subdivision - April - June 2010

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00073*FD	May 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	4.3	5/1/2010
2PG00073*FD	May 2010	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	4.3	5/8/2010
2PG00073*FD	June 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	3.94	6/1/2010
2PG00073*FD	June 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.15	.19387	6/1/2010
2PG00073*FD	June 2010	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	3.94	6/15/2010

Get New  
Data

Get Detail  
for Selected  
Permit

## Facilities in Significant Non-Compliance \*\*

Period: Jan-10 Jun-10

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signlf Exceed (1)**	# Months Exceed (2)**
Auglaize	2PG00073	Beverly Hills Subdiv			1 00610	Nitrogen, Ammonia (NH3)	115	2	2

### Footnotes

#### for Significant NonCompliance

\*\* Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
  - a. 40% for Group 1 pollutants **plus Fecal Coliform**
  - b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**-- or --
2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:

- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.