



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 31, 2009

Re: North Hampton
Clark County
Community Water System
PWS ID: 1203412

Troy Wildman
North Hampton Village
P.O. Box 307
North Hampton, Ohio 45349

Subject: Monthly Operating Report, Failure to Submit

Dear Mr. Wildman:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of June 2009, the Village of North Hampton public water system failed to send the monthly report to this office. This is a violation of the rule. The Village of North Hampton public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at (937) 285-6085.

Sincerely,

Tya Darden
Division of Drinking and Groundwaters
Public Drinking Water Unit

CC: DDAGW, CO
File
Ec: Clark County Health Department