



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 29, 2009

Re: North Hampton
Clark County
Community Water System
PWS ID: 1203412

North Hampton Village
Attn: Troy Wildman
P.O. Box 307
North Hampton, OH 45349

Subject: Monthly Operating Report, Failure to Submit

Dear Mr. Wildman:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **November 2009**, the Village of North Hampton public water system failed to send the monthly report to this office. This is a violation of the rule. The Village of North Hampton public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

Tya Darden

Division of Drinking and Groundwaters
Public Drinking Water Unit

cc: Dave Bornino, Ohio EPA, DDAGW, CO
Clark County Health Department
Board of Directors

TD/mab