



State of Ohio Environment

OH7902303

Roswell, Village of

12/3/2008

STREET ADDRESS:

Lazarus Government Center
50 W Town Street, Suite 700
Columbus, OH 43215

TELE: (614) 644-3020 FA
www.epa.state



December 3, 2008

ROSWELL, VILLAGE OF
5198 MAIN ST
NEW PHILADELPHIA, OH 44663

Re: TUSCARAWAS COUNTY
ROSWELL PWS
Community Water System
PWS ID: OH7902303

NOTICE OF VIOLATION - ACTION REQUIRED

Subject: Failure to Monitor Drinking Water

Roswell Pws is in violation of Ohio Administrative Code Rule 3745-81-24 for failing to monitor your drinking water during the July 1, 2008 to September 30, 2008 monitoring period and/or report results for the following contaminants: TOTAL HALOACETIC ACIDS (HAA5), TOTAL TRIHALOMETHANES (TTHM)

In order to return to compliance, Roswell Pws must take the following actions:

1. Immediately collect a sample of your drinking water from the maximum residence time (location in system where age of water is oldest).
2. Submit the sample for analysis to a certified laboratory on the enclosed list.
3. Notify your customers using the enclosed instructions and public notice.
4. Complete and return the enclosed verification form to this office.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or if the required sample was tested, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form; Laboratory List
cc: Superintendent/Manager; DDAGW-SEDO file; DDAGW-CO file