



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Notice of Violation  
Auglaize County  
Cridersville WWTP  
Ohio EPA Permit No. 2PB00048  
NPDES Permit No. OH0020222

March 5, 2009

Mr. John J. McDonald, Village Administrator  
Village of Cridersville  
110 W. Main Street  
Cridersville, Ohio 45806

Dear Mr. McDonald:

We are in receipt of your self-monitoring report covering the months of October 2008, through December 2008, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of non-compliance are attached on a separate sheet.


We have received your email dated November 19, 2008, regarding the above referenced violations. No further response is needed. We are aware that the Village has contracted with Floyd Browne Group to upgrade the WWTP and that it has obtained compliance with all limits in November and December. However, we must also remind the Village that it is still in non-compliance with the schedule of compliance contained in its NPDES permit. If effluent violations continue to occur or the schedule of compliance in the Village's NPDES permit is not met, it may be necessary to recommend that the Director take enforcement action pursuant to Ohio Revised Code Chapter 6111 to bring the Village into compliance with its NPDES permit.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

Mr. John J. McDonald  
March 5, 2009  
Page 2

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams  
Division of Surface Water

/llr

Enclosure

(pc w/enclosure: [DSW-NWDO File - ])

Get New Data

Cridersville WWTTP violations for October-December 2008

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00048*HD	October 2008	001	01119	Copper, Total Recovers	30D Conc	30	53.5	10/1/2008
2PB00048*HD	October 2008	001	01119	Copper, Total Recovers	1D Conc	51	79.	10/14/2008