



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Auglaize County
Cridersville WWTP
Ohio EPA Permit No. 2PB00048
NPDES Permit No. OH0020222

June 25, 2009

Mr. John J. McDonald, Village Administrator
Village of Cridersville
110 W. Main Street
Cridersville, Ohio 45806

Dear Mr. McDonald:

We are in receipt of your self-monitoring report covering the months of January through March 2009, for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of non-compliance is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. We are aware that the Village has contracted with Floyd Browne Group to upgrade the WWTP, however, we must also remind the Village that it is still in non-compliance with the schedule of compliance contained in its NPDES permit. If effluent violations continue to occur or the schedule of compliance in the Village's permit is not met, it may be necessary to recommend that the Director take enforcement action pursuant to Ohio Revised Code Chapter 6111 to bring the Village into compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs.

Mr. John J. McDonald, Village Administrator
June 25, 2009
Page 2

For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams
Division of Surface Water

/llr

Enclosure

~~pc w/enclosure: DSW-NWDO File~~

Get New Data

| Permit No | Reporting Period | Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|-------------|------------------|---------|----------------|-----------|------------|-------|----------------|----------------|
| 2PB00048*HD | March 2009 | 001 | 00400 | pH | 1D Conc | 9.0 | 9.7 | 3/2/2009 |