



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-6461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Auglaize County
Cridersville WWTP
Ohio EPA Permit No. 2PB00048
NPDES Permit No. OH0020222

August 17, 2009

Mr. John J. McDonald
Village Administrator
Village of Cridersville
110 W. Main Street
Cridersville, Ohio 45806

Dear Mr. McDonald:

We are in receipt of your self-monitoring report covering the months of April through June 2009 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of non-compliance is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,

Justin A. Williams
Division of Surface Water
/csl

Enclosure

Pc w/Enclosure: NWDO – DSW File.

Get New Data

Violation for Criddersville WWTTP - April - June 2009

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00048*HD	May 2009	001	31616	Fecal Coliform	7D Conc	2000	2306.51	5/8/2009