



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Auglaize County
G.A. Wintzer & Son Company
Ohio EPA Permit No.21K00002
NPDES Permit No. OH0002593

March 9, 2010

Mr. Carl C. Wintzer
Vice President
G.A. Wintzer & Son Company
P.O. Box 406
Wapakoneta, OH 45895

Dear Mr. Wintzer:

We are in receipt of your self-monitoring report covering the months of October through December 2009 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is attached on a separate sheet.


We have received your response dated November 7, 2009, for the referenced violation and require no further information at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,


Justin A. Williams
Division of Surface Water

/lb
Enclosure

Pc w/Enclosure: ~~NWDO-DSW.File~~

Get New Data

Violation for G.A. Wintzer & Son Company - October - December 2009

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2IK00002*ED	October 2009	001	00530	Total Suspended Solids	1D Conc	30	33.	10/2/2009