



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Auglaize County
Beverly Hills Subdivision
Forest Lane Subdivision
(K/Z Sewer District)
New Knoxville WWTP
Pleasantview Estates Subdivision
Sheerwood Forest Subdivision

December 10, 2007

Mr. Douglas P. Reinhart
Auglaize County Engineer
P.O. Box 59
Wapakoneta, OH 45895

Dear Mr. Reinhart:

We are in receipt of your self-monitoring reports covering the months of July 2007 through September 2007 for the referenced facilities. Our review indicates violations of the conditions of those NPDES permits. The specific instances of noncompliance are attached on separate sheets. Further review of your self-monitoring reports for the previous six months, ending in September 2007, for Forest Lane Subdivision indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions:

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention,

Get New Data

Violations for K/Z Sewer District - July thru September 2007

Permit No	Reporting Period	Station	Reportin g Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PW00006*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	2.6	7/1/2007
2PW00006*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.5	2.6	7/22/2007

Permit No	Reporting Period	Violation			Reporting Code	Parameter	Sample		
		Date	Station	Station			Frequency	Expected	Reported
2PW00006*AD	July 2007	7/1/2007	001	50060	Chlorine, Total Residu	1/2Weeks	1	0	
2PW00006*AD	July 2007	7/15/2007	001	50060	Chlorine, Total Residu	1/2Weeks	1	0	
2PW00006*AD	August 2007	8/1/2007	001	50060	Chlorine, Total Residu	1/2Weeks	1	0	
2PW00006*AD	August 2007	8/15/2007	001	50060	Chlorine, Total Residu	1/2Weeks	1	0	
2PW00006*AD	September 2007	9/1/2007	001	50060	Chlorine, Total Residu	1/2Weeks	1	0	
2PW00006*AD	September 2007	9/15/2007	001	50060	Chlorine, Total Residu	1/2Weeks	1	0	