



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Auglaize County
K/Z Sewer District
New Knoxville WWTP
Pleasantview Estates Subdivision
Sharlon Subdivision
Uniopolis WWTP

February 27, 2008

Mr. Douglas P. Reinhart
Auglaize County Engineer
P. O. Box 59
Wapakoneta, Ohio 45895

Dear Mr. Reinhart:

We are in receipt of your self-monitoring reports covering the months of October 2007, through December 2007, for the referenced facilities. Our review indicates violations of the conditions of those NPDES permits. The specific instances of noncompliance are attached on separate sheets. This letter also serves as notice that we have not received your December 2007, self-monitoring reports for New Knoxville WWTP stations 001 and 601. As a reminder hard copy self-monitoring report submissions are due on the 15th day of the following month and electronic submissions are due on the 20th day of the following month. Submit your missing December 2007, reports **within 10 days** of the date of this letter.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction).

Mr. Douglas P. Reinhart
February 27, 2008
Page 2

For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams
Division of Surface Water

/llr

Enclosure

pc.w/enclosure:DSW-NWDO:File (5)

Get New Data

Violations for K/Z Sewer District - October - December 2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PW00006*AD	December 2007	001	00530	Total Suspended Solids	30D Conc	12	67.	12/1/2007
2PW00006*AD	December 2007	001	00530	Total Suspended Solids	30D Qty	0.45	1.57229	12/1/2007
2PW00006*AD	December 2007	001	80082	CBOD 5 day	30D Conc	10	12.41	12/1/2007
2PW00006*AD	December 2007	001	00530	Total Suspended Solids	7D Conc	18	67.	12/15/2007
2PW00006*AD	December 2007	001	00530	Total Suspended Solids	7D Qty	0.68	1.57229	12/15/2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
2PW00006*AD	October 2007	001	50060	Chlorine, Total Residu	1/2Weeks	1	0	10/01/2007
2PW00006*AD	October 2007	001	50060	Chlorine, Total Residu	1/2Weeks	1	0	10/15/2007