



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Notice of Violation  
Auglaize County  
Arrowhead Estates Subdivision  
Beverly Hills Subdivision  
Forest Lane Subdivision  
K/Z Sewer District  
New Knoxville WWTP  
Pleasantview Estates Subdivision  
Sharlon Subdivision  
Sherwood Forest Subdivision  
Uniopolis WWTP  
NPDES Permits

November 14, 2008

Mr. Douglas P. Reinhart  
Auglaize County Engineer  
P.O. Box 59  
Wapakoneta, OH 45895

Dear Mr. Reinhart:

We are in receipt of your self-monitoring reports covering the months of April 2008 through September 2008 for the above referenced facilities. Our review indicates violations of the conditions of those NPDES permits. The specific instances of noncompliance are attached on separate sheets. Further review of your self-monitoring reports for Arrowhead Estates Subdivision, and Pleasantview Estates Subdivision for the previous six months, ending in September 2008, indicates that you are in significant non-compliance (SNC) with several effluent limitations contained in your NPDES permits. The specific instances of SNC are attached on separate sheets.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner.

Mr. Douglas P. Reinhart  
November 14, 2008  
Page 2

You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 - 3022.

Sincerely,




Justin A. Williams  
Division of Surface Water

/csl

Enclosure

pc: w/Enclosure: NWDO File (9)



K/Z Sewer District July - September 2008 Violations

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PW00006*AD	July 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.8	7/17/2008
2PW00006*AD	July 2008	001	00400	pH	1D Conc	9.0	9.5	7/24/2008
2PW00006*AD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	9/11/2008
2PW00006*AD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.8	9/25/2008