



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 17, 2011

RE: AMRESKO INC
3GR00024*DG
STORMWATER
CUYAHOGA COUNTY

Mr. Chris Smith
Compliance Supervisor
Amresco LLC
6681 Cochran Road
Solon, OH 44139

Dear Mr. Smith:

On June 13, 2011 this writer conducted an inspection of your facility, located at 30175 Solon Industrial Parkway, Solon, Ohio to determine compliance with your Industrial General Storm Water NPDES permit referenced above. Along with my observations from the inspection I have provided comments concerning your permit below:

General:

1. This site is the location of Amresco Inc., a company which manufactures chemicals for life sciences.

Inspection Observations:

1. Several storm drain catch basins were located on the north side of the building in the gravel parking lot. These basins should be cleaned out and checked regularly in order to provide room for sediments and debris to settle and keep them from entering the storm system.

Permit:

1. The correct NPDES permit number to list on the cover of the Storm Water Pollution Prevention Plan (SWPPP) can be found in the top right corner of this letter.
2. A Pollution Prevention Team must be identified and included in the SWPPP as required in paragraph D.1 of part IV of the permit.
3. The SWPPP should include a Non-Storm Water Discharges certification as required in Paragraph D.3.g in Part IV of the permit. This statement certifies that discharge has been tested or evaluated (does not necessarily require discharge sampling) for the presence of non-storm water discharges. The certification shall include:

Mr. Chris Smith
Amresco Inc.
June 17, 2011
Page 2


- a. The identification of potential significant sources of non-storm water at the site.
 - b. A description of the results of any test and/or evaluation for the presence of non-storm water discharges.
 - c. The evaluation criteria or testing method used, the date of any testing and/or evaluation.
 - d. The on-site drainage points that were directly observed during the test.
4. An inventory of exposed materials and potential pollutant sources should be listed in the SWPPP as required in paragraph D.2 in part IV of the permit.

Action Items

- Clean out catch basins behind building in gravel lot.
- Make aforementioned changes to SWPPP.

If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1125 or by email kelly.mcvay@epa.ohio.gov.

Sincerely,



Kelly A. McVay
Assistant to the District Engineer
Division of Surface Water

KAM/mt