



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 20, 2009

RE: ASW SUPPLY CHAIN SERVICES LLC
3GR01093*DG
STORMWATER
SUMMIT COUNTY

Mr. Michael Filippi
General Manger
ASW Global
3375 Gilchrist Road
Mogadore, Ohio 44260

Dear Mr. Filippi:

On August 5, 2009 this writer conducted an inspection of your facility to determine compliance with your Industrial General Stormwater NPDES permit referenced above. Besides you, Teresa Dennewitz, ASW Global, David Rischar and Cory Harris, Ohio EPA, were present. The following observations were made:

General

ASW Supply Chain is a warehouse distribution center which also provides design consultation services in the area of product shipping and distribution. Applicable SIC Codes are 4226 and 2821 as identified on the current NOI application. The site is served by city sewers and municipal water.

Inspection observations

- 1) Most of the site is overlain with concrete and storm sewers transfer stormwater to a retention pond at the entrance near Gilchrist Road. There were no visual problems noted with the storm sewers or the pond.
- 2) The site is relatively clean, however at the time of the inspection there was one minor item of concern located at the railway on the north side of the property. At the unloading area located at the northwest corner of the east building, plastic pellets were observed in the area close to a catch basin. You explained that normally during loading a pan is used underneath the piping from the rail car to the building. On the day of the inspection, the pan was not in use. We did note that your catch basins in the area are equipped with screens to catch any stray pellets, preventing them from entering the storm sewers.

Please be aware of your Stormwater General Permit and the requirement to create a Stormwater Pollution Prevention Plan. The plan should be evaluated once per year and updated as necessary. It must be kept on file at your office and be available upon request. If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1136.

Sincerely,

Philip P. Rhodes P.E.
Environmental Specialist II
Division of Surface Water

PPR/mt

File: Stormwater