



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

August 23, 2010

RE: CLEVELAND SHIPREPAIR CO.
3GR00402*DG
STORMWATER
CUYAHOGA COUNTY

Mr. Kyle J. Fries
General Manager
Cleveland Shiprepair Co.
1847 Columbus Rd.
Cleveland, Ohio 44113

Dear Mr. Fries:

On August 9, 2010 this writer conducted an inspection of your facility, located at 1847 Columbus Road in Cleveland, to determine compliance with your Industrial General Storm Water NPDES permit referenced above. Along with my observations from the inspection, I have provided comments concerning your Stormwater Pollution Prevention Plan (SWPPP) below:

General:

1. This site handles repairs of ships both on site and at other docks around Cleveland. The company's services include fabricating, welding, rigging, and industrial maintenance services.
2. Fabrication and small repairs are done inside the main building and larger jobs are done either at the dock outside the building or at the dock where the ships are docked.

Inspection Observations:

1. Fuel for the tow motors is stored outside within secondary containment. However I would suggest that you move the tank from the corner of the building near to the storm drain to a more secluded protected location away from heavy traffic and storm drains. This is due to the direct link between the storm drain and the Cuyahoga River.

SWPPP:

1. The site map needs to be created and the following should be included:
 - a. Identify and locate on map all stormwater outfall location points with designated number (e.g. 001, 002, etc.).
 - b. Overall drainage patterns (which areas drain into each outfall).
 - c. Location of all storm sewers and sanitary sewers with direction of flow, including where all catch basins drain.

Mr. Kyle J. Fries
Cleveland Shiprepair Co.
August 23, 2010
Page 2

- d. Location of potential sources of pollutants such as tank farms, raw material storage, waste material storage, dumpsters, loading/unloading docks, air pollution control equipment (e.g. bag houses, exhaust fans). List to included any outside sources whether isolated or not.
- e. Site acreage with estimate of impervious surface vs. pervious surface.

Action Items

- Update site map and keep the map in the SWPPP.

If you should have any questions concerning this letter, feel free to contact this writer at (330) 487-1708 or by e-mail david.rischar@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink, appearing to read 'D. R.', with a large, stylized flourish extending from the end of the signature.

David Rischar
Assistant to the District Engineer
Division of Surface Water

DR/mt