



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 6, 2010

RE: COLFOR MANUFACTURING, INC
MINERVA OPERATIONS
3GR01225*DG
STORM WATER
CARROLL COUNTY

Mr. Jamie Greiner
Colfor Mfg. Machining Division
Minerva Operations
461 Knox Court
Minerva, Ohio 44657

Dear Mr. Mann:

On January 5, 2010, this writer conducted an unannounced inspection of your facility for the purpose of determining compliance with the above referenced NPDES permit and the elimination of the individual NPDES permit application that was submitted. Colfor Manufacturing was represented by you during the inspection. The following is a summary of the visit:

Colfor Manufacturing, Inc, Minerva Operations, located at 461 Knox Court, Carroll County, manufactures automotive parts. Colfor is an Industrial User and discharges the cooling tower blow down to the Village of Minerva sanitary sewers, tributary to the Minerva WWTP. On the day of the inspection there were no visual problems noted at the discharge point for the storm water system, an unnamed tributary of Sandy Creek, or immediately downstream.

Other than storm water, there are no authorized direct discharges to waters of the state. In general, the site regarding the potential for exposure of pollutants to storm water is low. Areas that would be of concern, such as the dumpster, roll off boxes, and outdoor storage materials are covered or do not pose a potential of exposure. Roll off boxes for cuttings are stored inside. This is a zero discharge facility; all industrial wastewater generated for production is captured and hauled off-site. Outdoor storage tanks have been provided with secondary storage.

At this time there is only a storm water discharge and the current general permit for this facility will be adequate. This office will shortly be forwarding the appropriate paperwork to Columbus to revoke the individual permit application submitted by the company in 2005. Since the cooling tower blow down has been connected to the sanitary sewer it is no longer necessary.

Mr. Jamie Greiner
Colfor Manufacturing, Inc, Minerva Operations
January 6, 2010
Page 2

We request that you submit an updated Storm Water Pollution Prevention Plan to this office no later than February 1, 2010. With the plan please include a site plan showing all surface drainage, roof drainage, and storm water control structures for the site.

If you should have any questions concerning this letter or the attached letter, feel free to contact the undersigned at (330) 963-1136.

Sincerely,

A handwritten signature in cursive script that reads "Joseph E. Trocchio".

Joseph E. Trocchio, P.E.
Environmental Engineer
Division of Surface Water

JET/mt

Attachment

File: Industrial Stormwater