

**Environmental  
Protection Agency**

Rep. Robert R. Sprague, Governor  
Lee Fisher, Lt. Governor  
Cathy Scatena, Director

June 25, 2010

RE: CROWE'S CABINETS INC  
3GR01213\*DG  
STORMWATER  
MAHONING COUNTY

Mr. Tim Crowe  
Crowe's Cabinets Inc  
725 South Hubbard Rd.  
Lowellville, Ohio 44436

Dear Mr. Crowe:

On June 21, 2010 this writer conducted an inspection of your facility, located at 725 South Hubbard Road in Lowellville, Ohio to determine compliance with your Industrial General Storm Water NPDES permit referenced above. Along with my observations from the inspection I have provided comments concerning your NPDES permit below:

General:

1. This site is the location of Crowe's Cabinets, manufacturers and suppliers of cabinets, countertops, and other similar products.

Permit:

1. A Storm Water Pollution Prevention Plan (SWPPP or SWP3) needs to be created for your Storm Water NPDES permit. The following link to the USEPA Web site provides guidance on preparing a SWPPP.  
[http://www.epa.gov/npdes/pubs/industrial\\_swppp\\_guide.pdf](http://www.epa.gov/npdes/pubs/industrial_swppp_guide.pdf)
2. The plan should contain a site map that shows the full site including contours of the site, direction of flow for storm water, the location of outflows, location of possible contaminations to storm water, location of all surface water bodies, and any BMPs that are currently in place.
3. The plan should contain specific storm water annual training dates and verification that training was conducted with the employees.
4. The following link to the USEPA website contains information pertaining to different sectors covered under the General Industrial permit. The Web site has links to resources for you to use to keep your site in compliance with your NPDES permit.

<http://cfpub.epa.gov/npdes/stormwater/swsectors.cfm>

Mr. Tim Crowe  
Crowe's Cabinets Inc  
June 25, 2010  
Page 2

Action Items

- Create an SWPPP

If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1125 or by email [lindsey.olmstead@epa.state.oh.us](mailto:lindsey.olmstead@epa.state.oh.us).

Sincerely,

A handwritten signature in black ink, appearing to read "L. Olmstead", written over a faint, illegible typed name.

Lindsey A. Olmstead  
Assistant to the District Engineer  
Division of Surface Water

LAO/mt