



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

June 9, 2010

RE: EATON CORPORATION  
3GR00255\*DG  
STORMWATER  
PORTAGE COUNTY

Mr. Edward Mulacek  
Eaton Corporation  
115 Lena Drive  
Aurora, OH 44202

Dear Mr. Mulacek:

On June 4, 2010 this writer conducted an inspection of your facility, located at 115 Lena Drive in Aurora, Ohio to determine compliance with your Industrial General Storm Water NPDES permit referenced above. Phillip Rhodes, Ohio EPA Environmental Specialist II, was also present during this inspection. Along with our observations from the inspection we have provided comments concerning your SWPPP below:

General:

1. This site is the location of Eaton Corporation, a reinforced hose and tube manufacturing company.
2. Storm water is directed through underground piping and catch basins to a retention pond located on site.

Inspection Observations:

1. While walking around the outside of the building we noticed a few areas of concern. The main area of concern was general trash cleanup. Trash around the trash compactor was located in the area of the nearby storm sewer.
2. The trash compactor was leaking hydraulic fluid.

Permit:

1. The SWP3 shall include a certification that the discharge has been tested or evaluated (does not necessarily require discharge sampling) for the presence of non-storm water discharges. The certification shall include:
  - a. The identification of potential significant sources of non-storm water at the site.

Mr. Edward Mulacek  
Eaton Corporation  
June 9, 2010  
Page 2

- b. A description of the results of any test and/or evaluation for the presence of non-storm water discharges.
  - c. The evaluation criteria or testing method used, the date of any testing and/or evaluation.
  - d. The on-site drainage points that were directly observed during the test.
2. Include the location of process water sewers in the site map.

Action Items

- Sweep around trash compactor and the nearby storm sewers as needed.
- Check the trash compactor for leaks and clean up fluid spills as needed.
- Add a non-storm water certification to the SWPPP.
- Add the location of processed water sewers to the site map.

If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1125 or by email [lindsey.olmstead@epa.state.oh.us](mailto:lindsey.olmstead@epa.state.oh.us).

Sincerely,



Lindsey A. Olmstead  
Assistant to the District Engineer  
Division of Surface Water

LAO/mt