

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 4, 2011

RE: FEDEX FREIGHT EAST AKRON  
3GR00775\*DG  
STORMWATER  
SUMMIT COUNTY

Mr. Bob James  
Service Center Manager  
FedEx Freight  
678 Killian Road  
Akron, Ohio 44319

Dear Mr. James:

On April 29, 2011 this writer conducted an inspection of your facility for the purpose of determining compliance with the above referenced General Stormwater Permit. FedEx Freight is located at 678 Killian Road, Akron, Summit County.

A review of the exterior of your facility noted the following:

- 1) The facility is relatively clean.
- 2) The loading/unloading dock areas are sloped away from the building and there were no trench drains present.
- 3) There are no storm drains located on the entire facility. All storm water is sheet flow runoff.
- 4) One uncovered roll off box was observed on the south side of the main building. Picture attached. The SWPPP indicated dumpsters are to be covered.
- 5) A fuel station for the trucks is located south of the main building. Picture attached.
- 6) There is a large building located on the south side of the property that was once an active fleet maintenance building. Only very light maintenance is done there now. There are floor drains and a pit located in the building. Reportedly, the drains are connected to an oil/water separator and then to the sanitary sewers.

A cursory review of your SWPPP was performed. It is acceptable. However, it should be updated on a yearly basis. The date of the review or revisions made should be indicated on the cover page. The last date indicated was 4/10/2009.

If you should have any questions concerning any of the above, feel free to contact this writer at (330) 963-1136 or by e-mail at [phil.rhodes@epa.state.oh.us](mailto:phil.rhodes@epa.state.oh.us).

Sincerely,



Philip P. Rhodes, P.E.  
Environmental Specialist II  
Division of Surface Water

PPR/mt

File: Industrial Stormwater

