



**Environmental
Protection Agency**

Gov. John Kasich, Governor
Lee Fisher, Lt. Governor
Chris Koroluk, Director

June 4, 2010

RE: JOHNSONITE
3GR00750*DG
STORMWATER
GEAUGA COUNTY

Mr. Jim Brown
Johnsonite
16910 Munn Rd
Chagrin Falls, OH 44023

Dear Mr. Brown:

On June 1, 2010 this writer conducted an inspection of your facility, located at 16910 Munn Rd in Chagrin Falls, to determine compliance with your Industrial General Storm Water NPDES permit referenced above. Charles Sahyers, Manager Facilities Maintenance and Lindsey Olmstead, Ohio EPA Assistant to the District Engineer were also present during this inspection. Along with our observations from the inspection we have provided comments concerning your SWPPP below:

General:

1. This site is a plastic extrusion plant, where powdered plastic resin is extruded and formed into finishing boarder/wall boards.
2. All storm water is diverted into a small retention basin that is used as a fire pond. The pond's outlet has a riser pipe that acts as an oil water separator.
3. The site has one storm water outfall (from the retention basin) that drains into an unnamed tributary of Bridge Creek.
4. The above ground storage tanks, located near the center of the property, contain powdered resin and are filled using tanker trucks. Drip pans are used when unloading the bulk products.

Permit:

1. Update the site map to include the following:
 - a. Overall drainage patterns
 - b. Site acreage with estimate of impervious surface vs. pervious surface.

If you should have any questions concerning this letter, feel free to contact this writer at (330) 487-1708 or by email david.rischar@epa.state.oh.us.

Sincerely,

David Rischar
Assistant to the District Engineer
Division of Surface Water

DR/mt