



**Environmental
Protection Agency**

John Kasich, Governor
Lee Fisher, Lt. Governor
Chris K. Fickel, Director

3 IN 0305
043216

June 23, 2010

RE: LINDE HYDRAULICS
3GR00914*DG
STORMWATER
MAHONING COUNTY

Mr. David Wright
Linde Hydraulics Corporation
5089 Western Reserve Rd
Canfield, OH 44406

Dear Mr. Wright:

On June 21, 2010 this writer conducted an inspection of your facility, located at 5089 Western Reserve Road in Canfield, Ohio to determine compliance with your Industrial General Storm Water NPDES permit referenced above. Along with my observations from the inspection I have provided comments concerning your SWPPP below:

General:

1. This site is the location of Linde Hydraulics Corporation, a company specializing in the design, production and repair of various hydraulic equipment including, high pressure pumps, motors, valves and transmissions.
2. Drainage on the site is directed through several catch basins to a retention pond located south of the main building. Water from the retention pond exits through a riser and discharges into a grassy area on site.
3. No production is conducted outside.

Permit:

1. The SWPPP should include the appropriate signatures as stated in paragraph G of Part VII of the NPDES General permit.

Action Items

- Add permanent or temporary covers to the trash and metal hoppers.
- Finish updating the SWPPP.
- Include signatures in the SWPPP.

If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1125 or by email lindsey.olmstead@epa.state.oh.us.

Sincerely,

Lindsey A. Olmstead
Assistant to the District Engineer
Division of Surface Water

LAO/mt