

**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

August 16, 2010

RE: MORGAN ELECTRO CERAMICS
3GR00972*BG
STORMWATER
CUYAHOGA COUNTY

Mr. William J. Hocevar
Facility Manager
232 Forbes Road
Bedford, OH 44146

Dear Mr. Hocevar:

On August 2, 2010 this writer conducted an inspection of your facility, located at 232 Forbes Road in Bedford, to determine compliance with your Industrial General Storm Water NPDES permit referenced above. I have provided comments concerning your Stormwater Pollution Prevention Plan (SWPPP) below:

General:

1. This site is manufacturer of technology-based materials, components and chemicals.
2. All production is conducted inside the main building. All process wastewater is collected and treated before being discharged to city sanitary sewers.
3. Only runoff from the parking lot flows into the storm drains.

SWPPP:

1. The site map needs to be created and the following should be included
 - a. Identify and locate on map all stormwater outfall location points with designated number (e.g. 001, 002, etc.).
 - b. Overall drainage patterns (which areas drain into each outfall).
 - c. Location of all storm sewers and sanitary sewers with direction of flow, including where all catch basins drain.
 - d. Location of potential sources of pollutants such as tank farms, raw material storage, waste material storage, dumpsters, loading/unloading docks, air pollution control equipment (e.g. bag houses, exhaust fans). List to included any outside sources whether isolated or not.
 - e. Potential sources of pollutants clearly identified on plan or by use of key.
 - f. Site acreage with estimate of impervious surface vs. pervious surface.

Action Items

- Update site map.

If you should have any questions concerning this letter, feel free to contact this writer at (330) 487-1708 or by email david.rischar@epa.state.oh.us.

Sincerely,



David Rischar
Assistant to the District Engineer
Division of Surface Water

DR/mt