

**Environmental
Protection Agency**

Tolson, Administrator, Governor
L. Michael, Lt. Governor
C. ... , Director

September 27, 2010

RE: PENNSYLVANIA CRUSHER CORP.
3GR00074 *DG
STORMWATER
SUMMIT COUNTY

Mr. Frank Special
Site System Administrator
601-607 Monroe Falls Avenue
Cuyahoga Falls, Ohio 44221

Dear Mr. Special:

On September 16, 2010, this writer conducted an inspection of your facility, located at 601-607 Munroe Falls Ave., Cuyahoga Falls, Summit County, to determine compliance with your Industrial General Storm Water NPDES permit referenced above. You accompanied me during the visit. Below you will find a summary of the inspection:

General:

Pennsylvania Crusher Corp. designs and manufacturers crushing equipment and replacement parts for the coal and rock industries. The facility is served by the City of Cuyahoga Falls for water and Akron for sewers. You did produce a SWPPP plan during the inspection. It was out of date, however, you did forward me the updated version via e-mail on September 17, 2010.

Inspection Observations:

- 1) There are no inside floor drains connected to the storm sewers.
- 2) Two refuse dumpsters were open during the inspection. The lids should be closed at all times when not in use.
- 3) Two roll off boxes were present, one for steel chips, the other for solid scrap steel. You indicated that the chip box is leak tight. Even so, it should be covered with at least a tarp when not in use.
- 4) There was oil staining on the pavement at the northwest corner of the building. It was leading to a storm drain. The source of the oil should be determined and the oil cleaned up so that it does not enter the drain.
- 5) There was water flowing in one of the storm drains. You indicated that this is noncontact cooling water from cooling the "Lucas" machines. Our records indicate that your company does not possess a NPDES permit for this discharge. It must be covered under an individual permit or a general permit. Please indicate to this writer which one you intend to obtain coverage. I would be glad to assist you with any questions you may have with this process.

MR. FRANK SPECIAL
SEPTEMBER 27, 2010
PAGE 2

SWPPP Plan Comments

- 1) A binder should be kept that includes the SWPPP, a copy of your NOI, a copy of the general permit, and all recent records such as training, inspection logs, etc.
- 2) The plan view of the property should clearly indicate the location of all storm sewers and storm inlets along with the direction of flow. Their discharge location off property must also be clearly identified. The same drawing should also locate the sanitary sewers.
- 3) When the chip bin is hauled off site by contractor, a person trained in spill response should be present to avoid a similar experience had in August 2007. Spill response material should be kept near the dumpster area.

If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1136 or by e-mail phil.rhodes@epa.state.oh.us.

Sincerely,



Philip P. Rhodes
Environmental Specialist II
Division of Surface Water

PPR:bo

File: Industrial Stormwater