



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Koraski, Director

September 13, 2010

**RE: PETERMAN LTD
3GR01207*DG
STORM WATER
SUMMIT COUNTY**

Donna Hurst
Peterman Ltd.
1033 Kelly Avenue
Akron, Ohio 44306

Dear Ms. Hurst:

On September 10, 2010 this writer conducted an inspection of your facility for the purpose of determining compliance with the above referenced storm water permit. You were present during the inspection.

Peterman Ltd., located at 1033 Kelly Ave., Akron, Summit County is a school bus terminal located on approximately 1.5 acres of land. Your SIC code is listed as 4151, school bus transportation. The site is used for bus storage and bus maintenance. During the inspection, your Storm Water Pollution Prevention Plan was reviewed. The plan was fairly complete. I had only three comments. The plan needs to be updated, as it was last updated in September 2008. It should be reviewed at least once per year. The certification statement must be signed by an official representing Peterman Ltd., not your consultant. The storm drains need to be clearly identified on the map of the property.

You stated that the buses are washed off in the gravel parking lot and that only water is used. Please be advised that run off from washing the trucks to adjacent properties or into a storm sewer is prohibited. Also, any type of soap or cleaner is not allowed in any circumstance. Noted during the inspection was two trench drains inside the bus garage. Both drained into a crock which contained an inverted pipe discharge. You are requested to verify in writing to this office, that the drains are actually connected to the sanitary sewers, not storm sewers.

If you should have any questions concerning any of the above, feel free to contact this writer at (330) 963-1136.

Sincerely,

Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR:cl

File: Industrial Storm Water