



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 14, 2011

RE: STP PRODUCTS MFG CO
3GR00175*DG
STORMWATER
LAKE COUNTY

Mr. Allan Mack
Technical Process Lead Processing
Clorox Co.
477 Lexington Avenue
Painesville, OH 44077

Dear Mr. Mack:

On June 13, 2011 this writer conducted an inspection of your facility, located at 477 Lexington Avenue, Painesville, Ohio to determine compliance with your Industrial General Storm Water NPDES permit referenced above. Along with my observations from the inspection I have provided comments concerning your permit below:

General:

1. This site is the location of Armored AutoGroup, Inc., a company that produces Armor All protectants, wheel cleaners, etc. and STP fuel additives.
2. The storm water on the site empties into parking lot drains which lead to a creek west of the property.
3. All waste water from inside the building and near the railroad track unloading area is collected in a containment tray below and sent to the oil-water separator. This water is then sent to sanitary.

Inspection Observations:

1. The only thing I noticed when walking around the exterior of the building was that the drains by the northeast docking area had filters in them which should be inspected and changed out regularly. Overall, this site was maintained very well and I did not see anything that was in violation of the permit.

Action Items

- Make sure filters are changed regularly and keep up with the good work.

If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1125 or by email kelly.mcvay@epa.ohio.gov.

Sincerely,

Kelly A. McVay
Assistant to the District Engineer
Division of Surface Water

KAM/mt