



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Auglaize County
Minster WWTP
Ohio EPA Permit No. 2PB00036
NPDES Permit No. OH0026573

February 6, 2008

Mr. Daniel P. Haehn
WWTP & WTP Superintendent
Village of Minster
P.O. Box 1
Minster, OH 45865

Dear Mr. Haehn:

We are in receipt of your self-monitoring report covering the months of October 2007 through December 2007 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is attached on a separate sheet.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,

Elizabeth A. Wick, P.E.
District Engineer/Unit Supervisor
Division of Surface Water

/csl

Enclosure

cc: w/Enclosure: NWD0 File

Get New Data

Violations for Munster WWTTP - October thru December 2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00036*JD	October 2007	001	00552	Oil and Grease, Hexane	1D Conc	10	13.5	10/10/2007