Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Notice of Violation
Auglaize County
New Bremen WWTP
Ohio EPA Permit No. 2PB00034
NPDES Permit No. OH0020346

October 5, 2010

Mr. Jerry Fischbach
WWTP Superintendent
Village of New Bremen
P. O. Box 27
New Bremen, Ohio 45869

Dear Mr. Fischbach:

We are in receipt of your self-monitoring report covering the months of April through June 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

We have received your email dated June 10, 2010, regarding the above referenced violations and require no further information at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's *"Facility Pollution Prevention Guide"* (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,

Justin A. Williams
Division of Surface Water

/cs
Enclosure
~~pc w/Enclosure: NWDO – DSW File~~

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

Get New Data

Violations for New Bremen WWTP - April-June 2010

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	2.0	3.58	5/1/2010
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	7D Conc	3.0	3.825	5/1/2010
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	30D Qty	6.8	10.8214	5/1/2010
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	7D Qty	10.2	12.0492	5/1/2010
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	7D Conc	3.0	3.22	5/8/2010
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	7D Conc	3.0	3.815	5/15/2010
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	7D Qty	10.2	13.8976	5/15/2010
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	7D Conc	3.0	4.225	5/22/2010
2PB00034*JD	May 2010	001	00610	Nitrogen, Ammonia (NH3	7D Qty	10.2	10.7739	5/22/2010