



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Notice of Violation  
Auglaize County  
New Bremen WWTP  
Ohio EPA Permit No. 2PB00034  
NPDES Permit No. OH0020346

June 8, 2011

Mr. Jerry Fischbach  
WWTP Superintendent  
Village of New Bremen  
P. O. Box 27  
New Bremen, Ohio 45869

Dear Mr. Fischbach:

We are in receipt of your self-monitoring report covering the months of January through March 2011, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

We have received your email dated March 8, 2011, regarding the above referenced violations and require no further information at this time.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Mr. Jerry Fischbach  
June 8, 2011  
Page 2

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams  
Division of Surface Water

/llr

Enclosure

{pc w/enclosure: DSW-NWDO File}

001 New Data

Village of New Bremen WWTTP - Violations for January - March 2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00034*KD	February 2011	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	44.0	61.5005	2/1/2011
2PB00034*KD	February 2011	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	65.0	97.0952	2/15/2011
2PB00034*KD	February 2011	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	65.0	84.9796	2/22/2011
2PB00034*KD	February 2011	001	80082	CBOD 5 day	7D Qty	51.0	64.9695	2/15/2011