



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

RE: Notice of Violation
Auglaize County
Quality Ready Mix, Inc.
Ohio EPA Permit No. 2IJ00086
NPDES Permit No. OH0119121

October 5, 2010

Mr. John Hirschfeld
President
Quality Ready Mix, Inc.
12201 Fryburg Rd.
Wapakoneta, OH 45895

Dear Mr. Hirschfeld:

We are in receipt of your self-monitoring report covering the months of April through June 2010 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violation, as well as a description of the actions taken or proposed to prevent any further violations.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,

Justin A. Williams
Division of Surface Water

/lb
Enclosure

Pc w/Enclosure: NWDO - DSW File

Get New Data

Violation for Quality Ready Mix, Inc. - April-June 2010

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2IJ00086*CD	April 2010	001	00530	Total Suspended Solids	1D Conc	45	81.	4/13/2010