



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

Re: Notice of Violation
Auglaize County
Thieman Stamping Company
Ohio EPA Permit No. 2IN00164
NPDES Permit No. OH0122289

June 25, 2009

Mr. Lindsay Miller
Environmental Coordinator
Thieman Stamping Company
P. O. Box 45
New Bremen, Ohio 45869

Dear Mr. Miller:

We are in receipt of your self-monitoring report covering the months of January through March 2009, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

We have received your response for the referenced violations and require no further information at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs.

Mr. Lindsay Miller
June 25, 2009
Page 2

For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,


Justin A. Williams
Division of Surface Water

/lr

Enclosure

pc-w/enclosure: DSW-NWDO.File

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2IN00164*AD	March 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	4.0	7.7	3/1/2009
2IN00164*AD	March 2009	001	00610	Nitrogen, Ammonia (NH3	7D Conc	6.0	7.7	3/8/2009