



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Auglaize County
Beverly Hills Subdivision
Forest Lane Subdivision
K/Z Sewer District
New Knoxville WWTP
Pleasantview Estates Subdivision
Sherwood Forest Subdivision
✓ Uniopolis WWTP
NPDES Permits

March 4, 2009

Mr. Douglas P. Reinhart
Auglaize County Engineer
P.O. Box 59
Wapakoneta, OH 45895

Dear Mr. Reinhart:

We are in receipt of your self-monitoring reports covering the months of October 2008 through December 2008 for the above referenced facilities. Our review indicates violations of the conditions of those NPDES permits. The specific instances of noncompliance are attached on separate sheets. Further review of your self-monitoring reports for Forest Lane Subdivision for the previous six months, ending in December 2008, indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

Mr. Douglas P. Reinhart
March 4, 2009
Page 2

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,



Justin A. Williams
Division of Surface Water

/csl

Enclosure

·Pc w/Enclosure: NWDO – DSW File (7)

Get New Data

Unriopolis WWTTP violations for October-December 2008

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PA00054*ID	October 2008	001	00400	pH	1D Conc	9.0	9.2	10/9/2008
2PA00054*ID	October 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.	10/9/2008
2PA00054*ID	October 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.2	10/16/2008
2PA00054*ID	October 2008	001	00400	pH	1D Conc	9.0	9.1	10/23/2008
2PA00054*ID	November 2008	001	00400	pH	1D Conc	9.0	9.4	11/6/2008
2PA00054*ID	November 2008	001	00400	pH	1D Conc	9.0	9.6	11/13/2008
2PA00054*ID	November 2008	001	00400	pH	1D Conc	9.0	9.2	11/20/2008