



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 27, 2012

RE: North Hampton
Clark County
Community Water System
PWS ID: 1203412

Mr. Troy Wildman
North Hampton Village
P.O. Box 307
North Hampton, OH 45349

Subject: Monthly Operating Report, Notice of Violation

Dear Mr. Wildman:

According to Ohio Administrative Code (OAC) 3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of March 2012, the village of North Hampton public water system failed to report both the free and total chlorine residual for the following dates: March 26, 27, 28, 30 and 31. This is a violation of the rule. Please clarify the term AN written on the report instead of the actual data.

The village of North Hampton public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at (937) 285-6085.

Sincerely,

Tya Darden
Environmental Specialist
Division of Drinking and Groundwaters
Public Drinking Water Unit

TD/tf

cc: Operations, Ohio EPA, DDAGW, CO
Clark County Health Department
Stephen Canter, Environmental Engineering Services

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov