



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH7704703

Tallmadge City PWS

1/11/2012



January 11, 2012

CERTIFIED MAIL

Bob O'Bryan
Tallmadge City PWS
210 Osceola Ave,
Tallmadge, OH 44278

Summit County
Tallmadge City PWS
Community PWS
PWS ID: OH7704703

Dear Public Water System Owner:

It has been determined that Tallmadge City was not in violation of the maximum contaminant level (MCL) for Haloacetic Acids, five (HAA5) during the July 1 through September 30, 2011 time period. Therefore, the MCL violation that was issued on November 17, 2011 is rescinded and Tallmadge City was not required to issue a public notice as outlined in the notice of violation.

Because Tallmadge City purchases its water from the City of Akron, and does not apply any additional treatment, the water system was regulated by Ohio Administrative Code (OAC) 3745-81-78 during July 1 through September 30, 2011 time period. This rule requires public water systems purchasing surface water to monitor for TTHM and HAA5, but exempts these systems from any MCL requirements. Please note that this rule expired on December 31, 2011 and Tallmadge City is now subject to all TTHM and HAA5 MCLs and monitoring requirements per OAC 3745-81-12 (A) and OAC 3745-81-24 (D) beginning January 1, 2012.

In order to remain in compliance, you must continue to monitor for all chemical parameters as indicated on your most recent monitoring schedule.

If you have any questions, please contact me at (614) 644-2752.

Sincerely,

Sarah Byerly
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form
cc: Manager; NEDO file; Summit County Health Department

50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 644 3020
614 | 644 3184 (fax)
www.epa.ohio.gov