



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

RE: Notice of Violation  
Auglaize County  
Wapakoneta WWTP  
Ohio EPA Permit No. 2PD00019  
NPDES Permit No. OH0027952

June 20, 2008

Mr. Robert Burns, Superintendent  
Wapakoneta WWTP  
P.O. Box 269  
Wapakoneta, OH 45895

Dear Mr. Burns:

We are in receipt of your self-monitoring report covering the months of January 2008 through March 2008 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

Mr. Robert Burns  
June 20, 2008  
Page 2

If there are any questions, please contact Mr. Justin Williams at (419) 373-3022.

Sincerely,



Elizabeth A. Wick, P.E.  
District Engineer/Unit Supervisor  
Division of Surface Water

/csl

Enclosure

ⓂPc w/Enclosure: NWDO File

Get New Data

Violations for Wapakoneta West P - January thru March 2008

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PD00019*KD	January 2008	001	80082	CBOD 5 day	7D Qty	227	265.058	1/8/2008
2PD00019*KD	March 2008	001	80082	CBOD 5 day	30D Qty	151	195.276	3/1/2008