



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Notice of Violation  
Auglaize County  
Waynesfield WWTP  
Waynesfield WTP

February 10, 2011

Mr. Fred Rowe  
Village of Waynesfield  
P. O. Box 476  
Waynesfield, Ohio 45896

Dear Mr. Rowe:

We are in receipt of your self-monitoring reports covering the months of October through December 2010, for the referenced facility. Our review indicates violations of the conditions of your NPDES permits. The specific instances of noncompliance are attached on separate sheets. Further review of the Waynesfield WWTP self-monitoring reports for the previous six months, ending in December 2010, indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is attached on a separate sheet.

Please inform this office in writing as to the reasons for the violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs.

Mr. Fred Rowe  
February 10, 2011  
Page 2

For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams  
Division of Surface Water

/lr

Enclosure

~~pcw/Enclosure: DSW-NWDO File (2)~~

Gen New Data

Waynesfield WUPP - Violations October - December 2010

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit Value	Reported Value	Violation Date
2PB00022*KD	November 2010	001	00530	Total Suspended Solids	30D Conc	30	36.75	11/1/2010

Get New Data

Get Detail for Selected Permit

### Facilities in Significant Non-Compliance \*\*

Period: Jul-10 Dec-10

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max. % Exceed	# Months Signif Exceed (1)**	# Months Exceed (2)**
Auglaize	2PB00022	Waynesfield WWTP		1	31616	Fecal Coliform	60	2	2

### Footnotes

#### for Significant NonCompliance

\*\* Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
  - a. 40% for Group 1 pollutants **plus Fecal Coliform**
  - b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**
- or --
2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:

- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.

Get New Data

Waynes Field WTP - Violations October - December 2010

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2IY00003*DD	December 2010	001	00530	Total Suspended Solids	1D Conc	45.0	74.	12/8/2010
2IY00003*DD	December 2010	001	00530	Total Suspended Solids	30D Conc	30.0	37.	12/1/2010
2IY00003*DD	December 2010	001	01044	Iron, Suspended (Fe)	1D Conc	2000	4650.	12/8/2010
2IY00003*DD	December 2010	001	01044	Iron, Suspended (Fe)	30D Conc	1000	2342.5	12/1/2010