



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Notice of Violation
Auglaize County
Waynesfield WWTP
Waynesfield WTP

June 9, 2011

Mr. Ronald Suter
Wastewater Operator
Village of Waynesfield
P. O. Box 476
Waynesfield, Ohio 45896

Dear Mr. Suter:

We are in receipt of your self-monitoring reports covering the months of January through March 2011, for the referenced facility. Our review indicates violations of the conditions of your NPDES permits. The specific instances of noncompliance are attached on separate sheets.

We have received your letter dated March 14, 2011, regarding the violations for January and February 2011, and require no further response for those violations. Please inform this office in writing as to the reasons for the March 2011 violations. Your response should contain a description of the actions taken or proposed to prevent any further violations and include the dates, either actual or proposed, for completion of the actions.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Mr. Ronald Suter
June 9, 2011
Page 2

If there are any questions, please contact me at (419) 373-3022.

Sincerely,


Justin A. Williams
Division of Surface Water

/lr

Enclosure

pcw/enclosure: _ DSW-NWDO.File.(2). _)

Print New Data

Violations for Village of Waynesfield WTP - January - March 2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
21Y00003*DD	February 2011	001	01044	Iron, Suspended (Fe)	30D Conc	1000	1069.5	2/1/2011
21Y00003*DD	March 2011	001	01044	Iron, Suspended (Fe)	1D Conc	2000	2310.	3/16/2011
21Y00003*DD	March 2011	001	01044	Iron, Suspended (Fe)	30D Conc	1000	1300.5	3/1/2011