



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Auglaize County
Waynesfield WWTP
Ohio EPA Permit No. 2PB00022
NPDES Permit No. OH0028029

November 14, 2008

Mr. David Chiles
Utility Superintendent
Village of Waynesfield
P.O. Box 476
Waynesfield, OH 45896

Dear Mr. Chiles:

We are in receipt of your self-monitoring report covering the months of April 2008 through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,

Justin A. Williams
Division of Surface Water
/csl

Enclosure

pc: w/Enclosure: NWDO – DSW File

Get New Data

Waynesfield WWTTP - April - June 2008 Violations

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00022*KD	April 2008	001	00530	Total Suspended Solids	7D Qty	21	21.2395	4/15/2008
2PB00022*KD	May 2008	001	00530	Total Suspended Solids	30D Qty	14	15.3883	5/1/2008
2PB00022*KD	May 2008	001	80082	CBOD 5 day	30D Qty	7.0	7.18191	5/1/2008
2PB00022*KD	June 2008	001	00530	Total Suspended Solids	30D Conc	30	30.25	6/1/2008

Permit No	Reporting Period	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
2PB00022*KD	May 2008	001	50050	Flow Rate	1/Day	1	0	05/14/2008