



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

RE: Notice of Violation
Auglaize County
Waynesfield WWTP
Ohio EPA Permit No. 2PB00022
NPDES Permit No. OH0028029

June 1, 2010

Mr. Lee Zeigler
Village of Waynesfield
P.O. Box 476
Waynesfield, OH 45896

Dear Mr. Zeigler:

We are in receipt of your self-monitoring reports covering the months of January through March 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

We have received your emails dated February 22, 2010 and March 24, 2010, regarding the referenced violations and require no further response at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.


Sincerely,

Justin A. Williams
Division of Surface Water

/lb

Enclosure

Pc w/Enclosure: ~~NWDO-DSW File~~



Violations for Waynesfield WWTTP - January - March 2010

| Permit No | Reporting Period | Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|-------------|------------------|---------|----------------|-------------------------|------------|-------|----------------|----------------|
| 2PB00022*KD | January 2010 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Conc | 7.0 | 8.52 | 1/1/2010 |
| 2PB00022*KD | January 2010 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Qty | 3.2 | 3.27655 | 1/1/2010 |
| 2PB00022*KD | February 2010 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Conc | 7.0 | 8.51 | 2/1/2010 |
| 2PB00022*KD | February 2010 | 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Qty | 3.2 | 3.29219 | 2/1/2010 |