



# Environmental Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH7741712

Silver Creek Christian Church PWS

11/30/2011



November 30, 2011

SILVER CREEK CHRISTIAN CHURCH  
4041 JOHNSON ROAD  
NORTON, OH 44203

Re: SUMMIT COUNTY  
SILVER CREEK CHRISTIAN CHURCH PWS  
Transient Noncommunity Water System  
PWS ID: OH7741712  
STU ID: 7758777

## DELINQUENCY NOTICE - ACTION REQUIRED

### Subject: Failure to Monitor Drinking Water

SILVER CREEK CHRISTIAN CHURCH PWS is in violation of Ohio Administrative Code Rule 3745-81-23 for failing to monitor your drinking water during the June 1, 2011 to October 31, 2011 monitoring period and/or report results for the following contaminants: NITRATE (AS N).

SILVER CREEK CHRISTIAN CHURCH PWS must promptly take the following actions.

- A. If sample was taken during this monitoring period,**
  - a. Call your laboratory and have them submit the results to Ohio EPA.
  - b. Contact this office at (614) 644-2752 to consult with us on this issue.

- OR -
- B. If sample was not taken during or after this monitoring period,**
  - a. Immediately take a sample of your drinking water from the first tap following treatment.
  - b. Submit the sample for analysis to a certified laboratory on the enclosed list.

- OR -
- C. If sample was taken after this monitoring period,** contact this office at (614) 644-2752.

Your prompt attention to this matter is appreciated. Continued failure to sample during your scheduled time period may lead to enforcement which may include penalties. If you have questions, please call me at (614) 644-2752.

Sincerely,

Wendy Sheeran  
Division of Drinking and Ground Waters

Enclosure: Laboratory List

cc: Superintendent/Manager; DDAGW-NEDO file; DDAGW-CO file

50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, Ohio 43216-1049

614 | 644 2752  
614 | 644 2909 (fax)  
www.epa.ohio.gov