




**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott A. Nally, **Director**



July 25, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. John Keyes  
Oakwood Village Water  
228 North First Street  
P. O. Box 457  
Oakwood, Ohio 45873

Paulding County  
Oakwood Village Water  
Community PWS

PWS ID: OH6300312

Dear Mr. Keyes:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were three (3) weeks during the month of June 2012, in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Oakwood has been in violation of OAC 3745-82-02 ten of the past twelve months. Review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Mr. John Keyes  
July 25, 2012  
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to [Chris.Riddle@epa.state.oh.us](mailto:Chris.Riddle@epa.state.oh.us).

Sincerely,

A handwritten signature in black ink, appearing to read 'C. Riddle', written in a cursive style.

Chris Riddle  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lr

pc: Tim Phillips  
Paulding County Health Department  
NWDO – DDAGW File