



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



NOTICE OF VIOLATION – ACTION

July 19, 2012

Mr. Dennis B. Brophy
Pacific NW Property Management
15685 SW 116th Street, #109
King City, Oregon 97224-2695

Ottawa County
Allen Park Mobile Court
Community PWS
PWS ID: OH6204112

Dear Mr. Brophy:

The Division of Drinking and Ground Waters (DDAGW) Plant – Distribution Monthly Operating Report (MOR) for the month of May 2012 was received as required by the Ohio EPA-Northwest District Office (NWDO) on June 9, 2012.

Review of the May 2012 MOR indicates that the analytical result (1.010 mg/L) for iron exceeds the secondary maximum contaminant level (SMCL). The Ohio Administrative Code (OAC) rule 3745-82-02 establishes the SMCL at (0.3 mg/L) for iron. OAC rule 3745-91-09 requires provision of treatment for removal of iron when an excessive amount of this substance is present in the untreated water.

Additionally, OAC rule 3745-83-01 (C) (1) requires each community water system to maintain a minimum of 0.2 mg/L free chlorine residual or 1.0 mg/L combined chlorine residual measured at representative points throughout the distribution system. OAC rule 3745-83-01 (F) (2) (a) requires that free and combined chlorine residual measurements be conducted at the plant tap and in the distribution system daily (7 days per week). Your operational report shows that measurements were not conducted 26 days during the month of May 2012.

If you have any questions regarding this letter, or any other matter involving your PWS, then contact me directly by telephone at (419) 373-3088 or via electronic messaging at jack.schwartz@epa.state.oh.us.

Sincerely,

John A. (Jack) Schwartz
Environmental Specialist 2
Division of Drinking and Ground Waters

JAS/cg

pc: Lorell Anderson, Park Manager
Zach Danzer, Maintenance Manager
Joseph L. St. Clair, Operator
Ottawa County Health Department
DDAGW, NWDO Correspondence File
ec: Justin Bowerman, DOCC, DDAGW, NWDO

