



**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



**NOTICE OF VIOLATION – ACTION REQUIRED**

July 19, 2012

Mr. Dennis B. Brophy  
Pacific NW Property Management  
15685 SW 116<sup>th</sup> Street, #109  
King City, Oregon 97224-2695

Ottawa County  
Allen Park Mobile Court  
Community PWS  
PWS ID: OH6204112

Dear Mr. Brophy:

The Division of Drinking and Ground Waters (DDAGW) Plant – Distribution Monthly Operating Report (MOR) for the month of June 2012 was received late by the Ohio EPA-Northwest District Office (NWDO) on July 12, 2012. Ohio Administrative Code (OAC) rule 3745-83-01 (I) (2) requires the submission of an operational report no later than the tenth of the month following the month being reported (i.e. June's monthly operational report should be submitted to the district office no later than July 10<sup>th</sup>).

OAC rule 3745-83-01 (F) (9) requires each community water system serving up to and including two-hundred fifty persons that provides ion exchange treatment to reduce hardness shall monitor for total hardness at least monthly at each entry point to the distribution system. Review of the June 2012 MOR indicates that the hardness operations test, which is required to be analyzed in a state-certified laboratory, was not included.

If you have any questions regarding this letter, or any other matter involving your PWS, then contact me directly by telephone at (419) 373-3088 or via electronic messaging at [jack.schwartz@epa.state.oh.us](mailto:jack.schwartz@epa.state.oh.us).

Sincerely,

John A. (Jack) Schwartz  
Environmental Specialist 2  
Public Drinking Water Unit  
Division of Drinking and Ground Waters

JAS/cg

pc: Lorell Anderson, Park Manager  
Zach Danzer, Maintenance Manager  
Joseph L. St. Clair, Operator  
Ottawa County Health Department  
DDAGW, NWDO Correspondence File  
ec: Justin Bowerman, DOCC, DDAGW, NWDO

