



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 4, 2009

RE: GULLIVERS 77 TRAVEL CENTER, INC.
3IN00322*BD
STARK COUNTY

Ms. Pamela Kerr
Gullivers 77 Travel Center, Inc.
2320 Faircrest Street, SW
Canton, OH 44706

Dear Ms. Kerr:

On July 28, 2009, this office conducted an inspection of your facility for the purpose of determining compliance with National Pollutant Discharge Elimination System (NPDES) permit 3IN00322*CD. Present during the inspection were this writer and Pamela Kerr, Gullivers 77 Travel Center, Inc.

At the time of the inspection there was no discharge from any of the three outfalls. Trash was noted in the stream on the west side of the property near outfall 3IN00322001. Also, hedge clippings were noted along the stream bank south of outfall 3IN00322002. The trash must be removed from the stream and placed in a dumpster. The hedge clippings are also to be removed and disposed of properly.

The receiving stream downstream of the discharge from the oil/water separator was clear with no visible oil sheen. Outfall 3IN00322003 must be made more easily accessible by clearing and maintaining a path to the outfall.


A review of your discharge monitoring reports (DMRs) covering the period September 2007 through June 2009 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
December 2007	003	pH	1D Conc	9.0	10.34	12/23/2007
December 2007	002	pH	1D Conc	9.0	9.21	12/23/2007
February 2008	002	pH	1D Conc	9.0	9.69	2/26/2008
March 2008	002	pH	1D Conc	9.0	9.92	3/31/2008
March 2008	002	Oil and Grease, Total	1D Conc	10	13	3/31/2008
March 2008	003	pH	1D Conc	9.0	10.67	3/31/2008
April 2008	002	Oil and Grease, Total	1D Conc	10	38	4/28/2008
June 2008	003	pH	1D Conc	9.0	9.58	6/23/2008
December 2008	003	pH	1D Conc	9.0	9.51	12/24/2008
February 2009	002	pH	1D Conc	9.0	10.75	2/18/2009
March 2009	002	pH	1D Conc	9.0	9.09	3/25/2009
March 2009	003	pH	1D Conc	9.0	10.39	3/25/2009
April 2009	002	pH	1D Conc	9.0	9.42	4/13/2009
May 2009	002	pH	1D Conc	9.0	9.24	5/6/2009
June 2009	003	pH	1D Conc	9.0	10.72	6/25/2009

MS. PAMELA KERR
AUGUST 4, 2009
PAGE 2

Should you should have any questions or comments regarding this letter, please contact this office at 330/963-1197.

Sincerely,

A handwritten signature in cursive script that reads "Dean Stoll".

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS:bo

pc: Craig Brechbuhler, Flynn Environmental, Inc.

File: Industrial Permit/Compliance