



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 5, 2010

RE: PORTAGE COUNTY
BP OIL PIPELINE-MOGADORE
OHIO EPA PERMIT NO. 3IG00003

Ms. Leanne Funke
HSSE Advisor
BP Oil Pipeline
4421 Bradley Road
Cleveland, OH 44109

Dear Ms. Funke:

On March 31, 2010 this writer conducted a compliance evaluation inspection of your facility referenced above. Mary Taylor, BP Oil, represented your company during the inspection. Below is a summary of the inspection:

BP Oil Pipeline, Mogadore Terminal is petroleum bulk storage facility handling diesel fuel and gasoline. The facility is permitted to discharge treated stormwater from two outfalls identified as 001 and 002. Outfall 001 discharges water from the east tank farm storage area containing two storage tanks and stormwater from the manifold area. Water collected is routed to a "mud vault" prior to an oil/water separator and then to two small ponds located on the northern boundary of the facility just inside the fence. Collected stormwater is usually pumped from the second pond unless stormwater flow is too large. A valve for a gravity drain then can be opened to discharge the stormwater by gravity.

Outfall 002 discharges water from the west tank farm storage areas. Water is collected in the dikes flowing by gravity to two ponds connected in series before discharging. This outfall is also valved to ensure that an accidental spill is contained on-site.

At the time of the inspection there was no flow and no obvious visual problems were observed. A compliance check of our SWIMS database indicated the following numeric violation of your NPDES permit for the time period of February 2009 through February 2010.

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2009	002	pH	1D Conc	6.5	6.2	8/3/2009

If you should have any questions concerning this letter, feel free to contact this writer at (330) 963-1136.

Sincerely,

Philip P. Rhodes, P. E.
Environmental Specialist II
Division of Surface Water

PPR/mt

File: Industrial Permit/Compliance