



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 8, 2009

Cargill Deicing Technology  
Cuyahoga County  
City of Cleveland  
NPDES Permit 3IE00042\*DD  
Notice of Violation

Mr. David Bird, Environmental Engineer  
Cargill Deicing Technology  
P. O. Box 6920  
Cleveland, OH 44101

Dear Mr. Bird:

This office is in receipt of your letter dated December 1, 2009, addressing noncompliance with the final effluent limitations of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of noncompliance are as follows:

Station	Date	Reporting Code	Parameter	Limit	Permit Limit	Reported Value
001	11/10/2009	00400	pH	Daily Conc	6.5 s.u.	6.3
001	11/23/2009	00400	pH	Daily Conc	6.5 s.u.	6.2

As required by Part III, General Conditions, of the NPDES permit, your letter addresses the reasons for the referenced violations and the actions taken or to be taken, to prevent any recurrences. Confirmation of the date of installation and proper operation of the timers must be confirmed in writing to this office.

Please be advised, failure to comply with the effluent limitations requirements of the NPDES permit may be cause for enforcement pursuant to the Ohio Revised Code chapter 6111.

If you should have any please contact this office at (330) 963-1124.

Sincerely,

Sandra M. Cappotto  
Environmental Scientist  
Division of Surface Water

SMC/mt