



**Environment
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 21, 2011

RE: EAST SPARTA WTP
3IY00040*CD
STARK COUNTY

Mr. Ralph Castelluci
Village of East Sparta
Water Treatment Plant
P.O. Box 357
East Sparta, OH 44626

36w 00005
12-1-10

Dear Mr. Castelluci:

On March 8, 2011, this writer conducted a compliance evaluation inspection of the wastewater treatment facility serving the East Sparta Water Plant. At the time of the inspection, the surface sand filter was flooded. The outfall was not observed as the pipe was under water due to the heavy rains and snow melt. Pictures of the filter are attached for your reference. A summary of the compliance history with the above referenced NPDES permit as identified by our SWIMS system for the time period of October 2007 through February 2011 is presented below:

Numeric Violations

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Iron, Suspended (Fe)	30D Conc	1000	1952.	2/1/2010
001	Iron, Suspended (Fe)	1D Conc	2000	3020.	5/3/2010
001	Iron, Suspended (Fe)	30D Conc	1000	3020.	5/1/2010
001	Iron, Suspended (Fe)	1D Conc	2000	2760.	4/6/2010
001	Iron, Suspended (Fe)	30D Conc	1000	2760.	4/1/2010
001	Iron, Suspended (Fe)	30D Conc	1000	1220.	3/1/2010
001	Total Suspended Solids	30D Conc	30	32.	5/1/2009
001	Iron, Suspended (Fe)	1D Conc	2000	2176.	5/11/2009
001	Iron, Suspended (Fe)	30D Conc	1000	2176.	5/1/2009

East Sparta Water Plant has applied for and obtained a general permit for water plants. The above referenced individual permit is still in effect but will expire June 30, 2011. Until it expires or is revoked, you must maintain compliance with both permits. We can revoke the individual permit, but will need confirmation from you that you that this is the desired course of action.

If you should have any questions, feel free to contact this writer at (330) 963-1136.

Sincerely,

Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR/mt

attachment

File: Industrial Permit\Compliance

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov

