



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 12, 2011

RE: KILLIAN LATEX
3IR00054
SUMMIT COUNTY

Mr. Tim Killian, President
Killian Latex, Inc.
2064 Killian Road
Akron, Ohio 44312

Dear Mr. Killian:

On June 30, 2011 this writer conducted a compliance evaluation inspection of your treatment system. The following was noted:

- 1) At the time of the inspection production was down, therefore no process wastewater was being discharged.
- 2) The pond was discharging at approximately 2 gallons per minute. The discharge was clear and no obvious problems were noted.

A review of your compliance history for the time period of April 2010 through May 2011 is provided below:

Numeric Violations

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Oil and Grease, Total	30D Qty	0.49	.75851	4/1/2010
001	Total Suspended Solids	30D Qty	1.36	2.04693	9/1/2010
001	Total Suspended Solids	1D Qty	2.03	2.04693	9/7/2010
001	pH	1D Conc	9.0	9.02	1/17/2011

Frequency Violations

None.

We also discussed the need to produce a Stormwater Pollution Prevention Plan, as required by your current NPDES permit. As discussed, the following is the USEPA website you can use in creating this plan:

<http://cfpub.epa.gov/npdes/stormwater/msgp.cfm>, under Sample MSGP SWPPP Template (WORD).

Mr. Tim Killian
Killian Latex, Inc.
July 12, 2011
Page 2

If you should have any questions, feel free to contact this writer at (330) 963-1136 or by e-mail at phil.rhodes@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink, appearing to read "Philip P. Rhodes". The signature is written in a cursive, flowing style.

Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR/mt

File: Industrial Permit/Compliance